

Board of Health Meeting  
December 7, 2017  
Town Building  
5:00 PM  
Agenda

5:00 PM- Call to Order

Minutes review November Meeting

Bills and Permits

**Appointments**

**5:15 PM-8 Davis Road- Sullivan, Connors and Associates**

*Applicant seeks relief from the following Local Upgrade Approvals*

- 1. Septic tank is less than 10' to property line (3' feet proposed).*
- 2. Separation between septic tank and proposed well is less than 50' (27' is proposed).*
- 3. Separation between leaching area and proposed well is less than 100' (56' is proposed).*
- 4. System is not designed at 150% capacity per Stow Board of Health Regulations.*

*Applicant seeks relief from Stow Board of Health Regulations*

- 1. Well is less than 15 ' to property line( 12'*
- 2. Well is less than 50 ' to building sewer( 26' is proposed)*
- 3. Well is less than 20' from foundation( 13'is proposed)*

**5:45 PM- Plantation II –Stow Elderly Housing Corporation**

Presentation of Proposed Septic Plans for Plantation II Development

**Discussion Items ( may be taken up at any time during the meeting)**

- FY19 Budget review
- Agent Report  
Barton Rd. area well testing update
- Member Reports
- Office Updates
- Medical Reserve Corps Updates  
4AB Updates- PHEP Budget
- Correspondence Review
- Review Public Hearing notices Town Departments

Adjournment

Posted 12.5.17