

planning2

From: building
Sent: Friday, May 28, 2021 2:07 PM
To: Jordan Mackey; Weston A. Fisher
Cc: building3; planning
Subject: FW: 271 Great Rd

Follow Up Flag: Follow up
Flag Status: Flagged

Hello Jordan, As discussed with you and Steve Quinn on 5/26/21, the following modifications to the exterior lighting shall be completed:

1. 4 Post Lights-Convert or replace each globe with a full cut off light fixture.
2. 4 Parking Lot lights can remain as is.
3. The full cut off lights on the street sign need to be down facing with no light spillover into Great Rd.
4. The small solar powered lights that are 6" from the ground are ok as is.

These items need to be addressed by 6/11/21 or enforcement action will be taken.

Sincerely,
Craig

Craig D. Martin, P.E.
Building Commissioner
Town Office Building
380 Great Road
Stow, MA 01775
Office 978/897-2193
Cell 508/561-3977

From: Craig Martin <craig.martin1946@icloud.com>
Sent: Friday, May 28, 2021 9:16 AM
To: building <building@stow-ma.gov>
Subject: 271 Great Rd







