

Board of Health Meeting
August 13, 2020
5:00 PM

Due to Coronavirus and the Town Building closure- The Board of Health will hold their meeting remotely on Zoom- to join the meeting see log in below

<p>5:00 -Call to Order Appointments/Hearings 5:30 PM- 18 Marlboro Road- Civil Solutions-Sewage System Upgrade-Failed Variances requested from Stow Board of Health Regulations:</p> <ol style="list-style-type: none">1. Reduction in the requisite groundwater offset from 5 feet to 3 feet with the use of Presby-Enviro-Septic System2. Allow the re-use of the existing 1500 Gallon single compartment septic tank.3. Allow reduction in the requisite offset from the leaching area to a wetland from 100 feet to 93 feet. <p>5:45 PM-238 West Acton Road-Civil Solutions- Sewage System Upgrade-Failed Variances requested from Stow Board of Health Regulations:</p> <ol style="list-style-type: none">1. Allow Reduction in the requisite groundwater offset from 4 feet to 3 feet with the use of Geo-mat System2. From Title 5 310 CMR 15.405 (l)(i) Allow the use of a sieve analysis where percolation test could not be performed due to groundwater interference.3. From Title 5 310 CMR 15.405(l)(j) Allow less than a 12 inch separation between inlets and outlets of the tanks and the high groundwater. Septic Tank and Pump chamber are required to be ordered with boots and risers are to be sealed to the tops of the tanks. <p>6:00 PM- 160 Whitman Street- Perley Engineering- Sewage System Upgrade 1. Local Upgrade Approval requested variance of a 1 foot reduction in the required height above groundwater.</p> <p>6:15 PM- 86 Boon Road- Sullivan, Connors & Associates- Sewage System Upgrade Variances requested:</p> <ol style="list-style-type: none">1. Leaching Bed separation to E.S.H.G.W less than 4 feet, 3 feet proposed2. Allow Sieve Analysis for percolation testing result3. Allow Tank inverts within 12 " of seasonal high groundwater <p>6:35 PM- 11 Westview Lane- Review Building Permit Clearance for finished basement additional 3 rooms</p> <p>Discussion Items(can be taken up at any time during meeting) Planning Board – Outdoor Dining Covid Updates-Reporting, Changes Governor’s Orders, Mask complaints, signage, CARES funding Lake Boon –Communication Plan Town Beach Agent Report Arbovirus Updates/EEE/Mosquito Control Member Updates Office Business- FY21 Bills, Permit updates FLU Clinic planning Public Comments Correspondence</p>
<p>Posted 8.11.20 5:00 PM cc Join Zoom Meeting https://zoom.us/j/92043130167?pwd=QmV4TIM5MkZvRS9HVThHRjIwQzZmdz09 Meeting ID: 920 4313 0167 Passcode: 851955 One tap mobile +13017158592,,92043130167#,,,,,0#,,851955# US (Germantown) +13126266799,,92043130167#,,,,,0#,,851955# US (Chicago) Dial by your location +1 301 715 8592 US (Germantown) +1 312 626 6799 US (Chicago) +1 929 205 6099 US (New York)</p>

+1 253 215 8782 US (Tacoma)
+1 346 248 7799 US (Houston)
+1 669 900 6833 US (San Jose)

Meeting ID: 920 4313 0167

Passcode: 851955

Find your local number: <https://zoom.us/j/92043130167>