



Town of Stow
Office of the
Procurement/Grants Administrator

380 Great Road
Stow, MA 01775
Tel: 978-216-2244

Ashley Pinard
Procurement/Grants Administrator
procurement@stow-ma.gov

Addendum #1

IFB 6-1-2023 Installation of Fire Protection Cistern

In response to questions raised during the pre-bid walk through on Monday May 22nd;

-The Cistern must be installed on the section of land that is owned by the town; this area is marked with plow stakes. The area to the right is conservation land and is not to be used for the Cistern installation. There is a map attached to the addendum, the shaded area shows the town owned land intended for the Cistern installation.

-The specific placement of the Cistern can be determined by the contractor, but the hydrant head must be accessible using a 10-foot suction hose from fire apparatus parked on the side of the road.

-Trees in the area of the installation may be removed but the contractor should not remove more trees than necessary.

-If a police detail is needed it will be paid for by the town, but the contractor is responsible for contacting the Stow Police Department for scheduling. The contractor should keep all vehicles and equipment on one side of the road keeping the road passable as often as possible.

-There is gas on the street in this neighborhood. It is the contractor's responsibility to request all necessary dig safes.